

Distribution Report

Monthly Report

June 2016

We started the 10th ave main project which involved boring 700' one day then pulling the six inch pipe back the next. Dug up and replaced a Waterous hydrant at 28th st and 12th ave. replaced a broken valve at 28th st and 11th ave. removed a hydrant at 3303 3rd ave. We also dug around the #3 elevated tank for the footing repair.

In addition we also did the following:

Fixed water leaks

- 120 35th st
- 195 35th st
- 2449 7th ave

Hydrant maintenance: 23

Service taps: 5

Measure new curb boxes: 5

Locates: 45

Hydrants loaded out: 6