

Distribution Report

Monthly Report

January 2014

There were a lot of water leaks this month again. Shut water off at 915 Blair Ferry Road for a broken 6" water line to their building. Turned curb stop box off in English Glenn for a broken water line that was flooding the condos. Filled hole in at 7th Avenue and 13th Street from a six inch hydrant line that broke. This line is due to be replaced and hydrant moved for parking space for the new 1317 7th Avenue building. We used the GPS unit and shot in 57 fire hydrants, shoveled snow, hauled dirt and concrete to Hanna Park, clean tools and equipment, washed the walls in wash bay then painted them with two coats of paint. We also built and repaired our barricades. Installed new frost teeth on the back hoe bucket as we are currently digging in frost that is 2-3 feet thick. Installed new electric motor in heater at well number six. Ran plants and continuing with map updates.

In addition we also did the following:

Fixed water leaks

- 7th AVE and 13th ST.
- 3221 1st ST.
- 1130 Maplecrest Dr.
- 1210 B- AVE
- 945 Orchard Rd.
- South 26th St. Ct.
- West 9th AVE and Hutton Hill
- 3001 Second St.
- 1135 Country Club Dr.
- 777 South 15th ST.

Hydrant maintenance: 3

Measure new curb boxes 6

Locates 1

Prepared by Curt Huhndorf