

Distribution Report

Monthly Report

September 2014

Finished Orchard Rd. water main relay. We will do yard work in spring. Dug trench at #5 plant for temporary power to #9 well. Installed two new water service lines for City of Marion projects at 1850 10th Street and 1000 Dry Creek Lane.

In addition we also did the following

Fixed water leak

- 700 Grand Ave

Leak holes repaired: 1

Yard work repaired: 8

Repair valve box: 1

Hydrants turned: 1

Service taps: 39

Measure new curb boxes: 17

Locates: 31

Hydrants loaded out: 5

Prepared by Curt Huhndorf