

Distribution Report

Monthly Report

January 2016

We repaired four main breaks in January. We tied the main together at 8th Ave and 31st Street. Started the Lowe Park main project which involved installing a tapping tee and valve. Installed roughly 300 ft. of eight inch C-900 before the frost went too deep.

Fixed water leaks

- 1740 Highview Dr
- 930 S-6th St.
- 3010 10th Ave
- 415 S-14th St.