

Distribution Report

Monthly Report

April 2018

April was a busy month we poured well # 10-meter pad removed and relocated two hydrants on 29th St one at 14th Ave the other was at 16th Ave for the city's sidewalk project. Fixed the 6-inch water main on 8th Ave that Quality excavating hit while tying the old services to the 12-inch water main. We also had to cut out 23 feet of 12-inch water main that M J Electric hit while boring in new electric lines for the roundabout at 6th Ave and 15th St.

In addition we also did the following:

Fixed water leaks

- 625 31st St.

Repair valve boxes: 1

Service taps: 43

Measure curb boxes: 43

Hydrants loaded out: 1