

Distribution Report

Monthly Report

August 2014

August was busy, worked on Orchard main relay, worked at 7th Ave and 13th St. with Rathje Construction to replace a ten inch valve and hydrant. Dug up at three different spots to disconnect 1100 feet of six inch water main on S 11th St.

In addition we also did the following

Repair valve boxes: 1

Hydrant maintenance: 2

Hydrants turned: 14

Service taps: 59

Measure new curb boxes: 36

Service orders: 35

Locates: 22

Hydrants loaded out: 6

Prepared by Curt Huhndorf